

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**CERTIFICATE**No. PHEE/KOR-I/Ws-133(G)/2025-26/ 987

Date : 25/07/2025

It is certified that an inspection team headed by Sri Sibasish Kar, DEO cum Sample Incharge DLL Kokrajhar from Public Health Engineering Department, Kokrajhar inspected the Bodoland Pioneer Public School, Kokrajhar Vill-Deborgaon, Kokrajhar BTR Assam on 23/07/2025 and on the basis of Water Test Report (Attached) ULR No TC14819 25000000259F dated 25/07/2025 of District Level Laboratory Kokrajhar certified that the Bodoland Pioneer Public School Kokrajhar has safe drinking water facilities for the students and members of staff of the institution and observed during the inspection that the authority is maintaining the hygienic sanitation condition in the school building & the campus of the institution.

The above is valid for a period of 6 Months from the date of issue,

Signature with Seal :


Executive Engineer (PHE)
Kokrajhar Division No.1
Kokrajhar

Name

: Er. Hitesh Rabha

Designation

: Executive Engineer (PHE)

Address:

O/o The Executive Engineer (PHE)
Kokrajhar Division No.1 Kokrajhar

To

The Administrator
Bodoland Pioneer Public School,
Kokrajhar



TC-14819

DISTRICT LEVEL LABORATORY KOKRAJHAR
OFFICE OF THE EXECUTIVE ENGINEER (PHE), KOKRAJHAR DIVISION NO.1
KOKRAJHAR, ASSAM PIN - 783370
Email id: dllkokrajhar@gmail.com

**TEST REPORT**

ULR NO	TC14819 25000000259F		
Source Type	Treated Water	Ref No.:BPPS/KOJ/CD/25/07/21-01 Date:21/07/2025	
Village/Address	Deborgaon	Block	Kokrajhar
Pin Point Location	Bodoland Pioneer Public School,Kokrajhar	Contact No	-
Sample Description:	Drinking water	Report Issue Date:	25/07/2025
Test Start Date:	24/07/2025	Date Of Receipt:	23/07/2025
Sample Condition	Good, Maintained at 4°C	Test End Date:	25/07/2025



Sample Collected By:	DLL Staff
Sample ID:	S30863992

Sr. No	Parameters	Methods	Units	Results	Acceptable Limits	Permissible limits
1	Colour	IS 3025 (Part 4)	Hazen units	<5	5	15
2	Odour	IS 3025 (Part 5)	-	Agreeable	Agreeable	Agreeable
3	pH at 25°C	IS 3025 (Part 11)	-	7.19	6.5 to 8.5	No relaxation
4	Taste	IS 3025 (Part 8)	-	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10)	NTU	0.5	1	5
6	Total dissolved solids	IS 3025 (Part 16)	mg/L	114	500	2000
7	Total Hardness (as CaCO ₃)	IS 3025 (Part 21)	mg/L	68	200	600
8	Total Alkalinity (as CaCO ₃)	IS 3025 (Part 23)	mg/L	95	200	600
9	Chloride(as Cl)	IS 3025 (Part 32)	mg/L	29.99	250	1000
10	Calcium(as Ca)	IS 3025 (Part 40)	mg/L	23.24	75	200
11	Magnesium (as Mg)	APHA 24th EDITION -3500-Mg Method B (By Calculation)	mg/L	2.43	30	100
12	Nitrate(as NO ₃)	IS 3025 (Part 34)	mg/L	1.52	45	No relaxation
13	Iron(as Fe)	APHA 24th EDITION -3500-Fe Method B (Phenanthroline Method)	mg/L	BDL	1	No relaxation
14	Fluoride(as F)	APHA 24th EDITION -4500-F Method D (SPADNS Method)	mg/L	0.21	1	1.5
15	Arsenic(as As)	IS 3025 (Part 37)	mg/L	BDL	0.01	No relaxation
16	Sulphate	IS 3025 (Part 24)	mg/L	2.27	200	400

Opinion: The Parameters tested above meet the requirement of IS 10500:2012 (Second Revision).

Note:

- The test report and result relate to the sample as received and tested in the laboratory
- The test reports shall not be reproduced in whole or in parts, without the prior consent of the laboratory.
- The test report is not intended for any publicity or any legal purposes.
- Any correction invalidates this test reports.
- The test sample meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless specified by customer for retaining over a longer period.
- BDL for arsenic (<0.009mg/l), Iron (<0.1mg/l), Fluoride (<0.1mg/l), Nitrate (<0.2mg/l), TDS (<5mg/l)

Tested by
(Dasharat Brahma)

Dasharat Brahma
Asstt. Chemist
DLL Kokrajhar (PHE)

LAB/QF-7.8
END OF REPORT

Authorized By
(Haina Brahma)

Haina Brahma for
NGDAL Officer (i/c)
DLL, Kokrajhar

DISTRICT LEVEL LABORATORY KOKRAJHAR
OFFICE OF THE EXECUTIVE ENGINEER (PHE), KOKRAJHAR DIVISION NO. I
KOKRAJHAR, ASSAM PIN - 783370
Email id: dllkokrajhar@gmail.com



TEST REPORT

Test Report No.	DLLKOK2025MBL0068		
Source Type	Filter	Work Order No.- NIL	
Village	Deborgaon	Block	Kokrajhar
Pin Point Location	Bodoland Pioneer Public School, Kokrajhar	Contact No	-
Sample Description:	Drinking water	Report Issue Date:	25/07/2025
Test Start Date:	24/07/2025	Date Of Receipt:	23/07/2025
Sample Condition	Good, Maintained at 4°C	Test End Date:	25/07/2025

Sample Submitted By:	DLL Staff
----------------------	-----------

Sr. No	Parameters	Methods	Units	Results	Acceptable Limits	Permissible limits
1	E coli	MF - Technique	CFU	0	No Relaxation	No Relaxation
2	Total Coliform	MF - Technique	CFU	0	No Relaxation	No Relaxation

__END OF REPORT__

Tested By

Disha Brahma

Microbiologist
DLL Kokrajhar
Kokrajhar Sub-Divn. No.1